Map ID MAP FINDINGS

Direction Distance

Distance Elevation Site EDR ID Number Database(s) EPA ID Number

 1077
 MH 1433
 NY Spills
 S107408378

 NNE
 OCEAN PARKWAY & AVENUE U
 N/A

> 1 BROOKLYN, NY

1.416 mi. 7477 ft.

Relative: SPILLS:
Higher Name: MH 1433

Actual: Address: OCEAN PARKWAY & AVENUE U

13 ft. City,State,Zip: BROOKLYN, NY Spill Number/Closed Date: 0506264 / 2005-10-14

 Facility ID:
 0506264

 Facility Type:
 ER

 DER Facility ID:
 298696

 Site ID:
 351437

 DEC Region:
 2

Spill Cause: Equipment Failure

 Spill Class:
 C4

 SWIS:
 2401

 Spill Date:
 2005-08-21

 Investigator:
 SKARAKHA

 Referred To:
 Not reported

 Reported to Dept:
 2005-08-21

 CID:
 62

Water Affected: Not reported
Spill Source: Commercial/Industrial
Spill Notifier: Responsible Party
Cleanup Ceased: Not reported
Cleanup Meets Std: False

Cleanup Meets Std: False
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0

Date Entered In Computer: 2005-08-22
Spill Record Last Update: 2005-10-14
Spiller Name: ERTS
Spiller Company: MH 1433

Spiller Address: OCEAN PKWAY AVE U

Spiller Company: 001 Contact Name: ERTS

DEC Memo: "e2mis no 160623 C.MARRAZZO #86127 FOD REPORTS FOUND APPROX 1-GALLON

OF DIELECTRIC FLUID THAT LEAKED FROM A 3W1W RAYCHEM JOINT ONTO DRY FLOOR FROM FEEDER 7B05 THAT OPENED AUTO IN MH-1433.IT APPEARS TO BE CONTAINED AT THIS TIME NO SEWERS OR WATERWAYS AFFECED NO FIRE OR SMOKE OR PRIVATE PROPERTY INVOLVED. 1-SAMPLE TAKEN FOR PCB ENVIR TAG

#48648 PLACED. CLEANUP PENDING TEST RESULT. Closed. 10-14-05. see

eDocs. GB'

Remarks: "Spill contained within manhole. Clean up pending sample results."

All Materials:

Site ID: 351437 Operable Unit ID: 1108955 Operable Unit: 01 2098929 Material ID: Material Code: 0541A Material Name: dielectric fluid Case No.: Not reported Material FA: Petroleum

Quantity: 1.00 Units: G

Map ID		MAP FINDINGS		
Direction		Ч		
Distance				EDR ID Number
Elevation	Site		Database(s)	EPA ID Number

Recovered: .00

Oxygenate: Not reported